



**Professional
Laboratory
Services**

13035 SW Pacific Hwy.
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT
ORELAP Accredited Lab#: OR-100013

Reported: 03/01/2017
Sampled: 02/15/17 08:30
Received: 02/15/17
Sampled By: Joey
Work Order: 7046065

C Crow Water Systems
L Attn: -
I PO Box 665
E Scappoose OR, 97056
N Phone: (503) 543-6326
T

Project:
PO #: -
Project #: N/A
Sampling Location: 1st Draw Sink Faucet
Sample Matrix: Water

Lab Number	Sample Name	Method	Result	Units	MRL	EPA MCL	Analysis Date/ Time	
7046065-01	South Columbia Family School							
	Sampled: 2/15/17 8:30							
	Copper	A	SM3111B	0.123	mg/L	0.050	1.3	03/01/17 14:40
	Lead	A	EPA 200.9	ND	mg/L	0.0020	0.015	02/16/17 14:08

ND = None detected **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit
A This analysis conforms to NELAC standards.

Approved by: Carrie Seidl
Carrie Seidl
Quality Assurance Director

This report shall not be reproduced, except in full, without the written approval of the laboratory.